

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 16/6/2025

It is certified that an inspection team headed by BIRENDRA SINGH MEHTA  
(Name of Officers with designation) from U.T.S., Almora PHED

inspected the Green Field Public School, Almora

(Name & Address of the school) on 16.6.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1161/UTS/DLWQTML/2025-26 dated 10.6.2025

of Uttarakhand Tal Sansthan Lab, Almora (PHED Lab) certified that the  
Green Field Public School, Almora (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 15.6.2026.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : U.T.S

To

Principal,  
Green Field Pub. Sch. Almora  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Almora**

Phone No.: 05962-2234049, E-mail: eealm.uj.s.uk@gmail.com


Test Report ID: 1161/UJS/DLWQTML/2025-26


Dated:10/06/2025

**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer	Green Field Public School, Jakhandevi, Almora		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	<b>SURFACE WATER</b>	<b>SAMPLE DESCRIPTION</b>	ONE WATER SAMPLE SUBMITTED FROM GREEN FIELD PUBLIC SCHOOL JAKHANDEVI, BLOCK-HAWALBAGH, ALMORA.
Reference Sample Identification:	DLWQTML/UJS/ALM-1161		<b>DATE OF START OF ANALYSIS</b> 09/06/2025
			<b>DATE OF END OF ANALYSIS</b> 10/06/2025
Date and Time of Sample Received: 09/06/2025 11:45AM	Sample Collected by:		Ms.Manju Devi

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.72	6.5 to 8.5	No Relaxation	IS 3025 Pt-11-2022
2.	Total Dissolved Solids (TDS), mg/L	100	500	2000	IS 3025 Pt-16-2023
3.	Turbidity, NTU	0.42	1	5	IS 3025 Pt-10-2023
4.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	60	200	600	IS 3025 (Part 23): 2023
5.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	62	200	600	IS 3025 (Part 21): 2009
6.	Colour, Hazen	Less than 5	5	15	IS 3025 (Part 4): 2021
7.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2022
8.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 1984
9.	Calcium (as Ca),mg/l	16.8	75	200	IS 3025 (Part 40): 2023
10.	Magnesium (as Mg), mg/l	4.86	30	100	APHA 23 <sup>rd</sup> -3500-Mg B-2023
11.	Chloride, mg/l	2.97	250	1000	IS 3025 (Part 32),2019,
12.	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA23rd ED-9223-B
13.	E.coli, MPN/100ML	Absent	Absent	Absent	APHA23rd ED-9223-B

  
(Lab Chemist)  
Pappu Bisht  
Chemist  
**Lab U. J. S., Almora**

  
Authorized Signatory  
(Assistant Engineer)  
Authorized Signatory  
District Water Quality Testing  
Monitoring Laboratory  
Uttarakhand Jal Sansthan, Almora

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
4. Result apply to the sample as received.
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.